


Disconnect Terminal Blocks

Breaking terminal block are usually used to measuring and controlling equipment so that the breakdown can be found out and fixed under the condition with voltage.



JMTK-P/P

Approval	CE
Insulating Material	PA66
Inflammability Class	UL 94 V ₀
Connection Standard	IEC 60947-7-1
Zack Strip	ZB5
Order Code	1010.061



JUK 5-MTK-P/P for testing screws

Approval	CE
Insulating Material	PA66
Inflammability Class	UL 94 V ₀
Connection Standard	IEC 60947-7-1
Zack Strip	ZB6
Order Code	1010.062



Technical Data

	JMTK-P/P	JUK 5-MTK-P/P
size	T5.2×H52×W46	T6.2×H62×W51
rated current	16A	16A
rated voltage	800V	800V
solid cross section (min)	0.2mm ²	0.2mm ²
solid cross section (max)	4mm ²	4mm ²
stranded cross section (min)	0.2mm ²	0.2mm ²
stranded cross section (max)	2.5mm ²	4mm ²
packing	50	50
connection type	screw connection	screw connection
Din Rail type	NS 35/7.5	1016.002
	NS 35/15	1016.003
	NS 32	1016.004

Accessories (P51-54)

	JMTK-P/P	JUK 5-MTK-P/P	
(1) end cover	grey		
(2) insertion bridge	poles: 2 poles	EB 2-5	1010.106
	3 poles	EB 3-5	1010.107
	10poles	EB 10-5	1010.108
(2) insertion bridge		EB 2-6	1010.109
		EB 3-6	1010.110
		EB 10-6	1010.111